

Warranty does not include malfunction due to clogged valve. Main air port is filtered with the supplied 80-100 micron integral-in-barb filter. Periodically check the filter for contamination and flow reduction, and clean with a brush or replace if needed (Part # PN004).

The surface between the manifold and pressure transducer is a pressure seal. Do NOT stress the circuit board or allow the manifold to move. Hold the manifold in one hand while installing pneumatic tubing onto the barbed fittings and use care when removing tubing to avoid damaging fittings or moving manifold. GAUGE POSITION ADJUSTMENT. If installation requires adjustment of the gauge for proper reading of the face, turn the gauge counterclockwise. O rings in the bottom of the gauge port will allow this without leakage.

This unit requires at least two cubic inches of branch air line capacity to operate without valve oscillation, and main air must be minimum of 2 psig above highest desired branch output pressure.

The input signal will not cause "wrap around" or start over if the upper range limit is exceeded.

CHECKOUT

SIGNAL INPUTS: Version #1 & 4: See jumper positions, page 1. Connect the pulse input positive (+) to the down (DN) terminal, and common to the signal common (SC) terminal. **Version #2:** Solidyne PWM signal and 0 -10 second Duty Cycle Pulse of Barber Colman™, Robertshaw™ or Staefa™. No pulse within 10 seconds = minimum output. Pulse equal or exceeding 10 seconds = maximum output. **Version #3:** For Staefa Smart II™ 0-20 Volt Phase Cut, 0-100% input connect Y to DN terminal, and common to SC (-) terminal. Trigger level above approx. 5% and below 95% of phase cut waveform (i.e. 5-95% min./max. or 5% lower and upper detection deadband). **Version #4** is reverse acting and will output minimum pressure at maximum signal, and maximum pressure at minimum signal. The EPW2 is factory calibrated at 0 psig minimum and 15 psig maximum output. This output can be re-calibrated to match the pressure range of the actuator using the GAIN and OFFset potentiometer as follows: (Note: The ZERO potentiometer is factory set. Do not adjust.).

1. Setting the minimum pressure. Make sure the signal input is disconnected. Place the OVERRIDE switch to the AUTO position. Drive the EPW2 to the minimum position by removing the 24V power connection for 3 seconds, then reconnect. Adjust the OFFset pot to the desired pressure output, or until the actuator just starts to move. The adjustment range of the OFFset pot is 0-10 psig.

2. Setting the maximum pressure. Now place the OVERRIDE switch to the MAN position. Turn the MANual pot full clockwise to produce the maximum branch line pressure available. Turn the GAIN pot for the maximum desired output pressure, or until the actuator just stops. The range of the GAIN pot is 10.5 to 20.0 psig. Be sure the MAIN air pressure is at least 2 psig greater than the desired maximum branch output pressure.

3. Repeat. Because the OFFset and GAIN pots are slightly interactive, steps 1 and 2 must be repeated until the desired minimum and maximum pressures are repeatable. Since the OVERRIDE pot is set for maximum pressure, it is only required that you switch the manual override back and forth from MAN to AUTO when repeating steps 1 and 2. Calibration is usually accomplished in less than 3 iterations. Now, select one of the four input timing ranges with the shunt as shown in Figure A.

Without power, the power and the status LED will not be illuminated. Apply power and the STATUS LED will blink slowly (twice per second), and the EPW2 will be at the lowest signal input state, or 0 psig. Apply minimum and maximum input signals and measure the response. **Version #1 & 4 Operation:** STATUS LED will flash quickly when EPW2 is receiving an input pulse, at the rate of the minimum resolution of the selected pulse range, (i.e. .1 to 25.5 second range, the LED will flash .1 second on, .1 second off). Exception: .59 to 2.93s range - LED remains constant. **Version #2 & 3 Operation:** .023-6 seconds - 1 flash, then pause. Staefa Phase Cut - 2 flashes, then pause. 0-10 second duty cycle - 3 flashes, then pause. **Version 4:** Same as Version #1 except output is reverse acting.

The input signal will NOT cause "wrap around" or start over if the upper range limit is exceeded. The pneumatic output changes when the input pulse has been completed. Pressure output between the minimum and maximum values will be linear, therefore software algorithms should be easy to derive. The feedback signal range on all selections is 0 to 5 VDC and is proportional to the output pressure range (Factory calibrated 0-15 psig).

The EPW2 incorporates two valves and is not a constant bleed interface. Its branch exhaust flow and response time is not limited by an internal restrictor and is similar to its load rate. If power is lost, the EPW2 will not exhaust any air from the branch line. The EPW2 is ideal for long branch line runs, multiple actuators, and outside air dampers because of its 750 scim capacity. The **FAIL SAFE** model, **EPW2FS**, will exhaust its branch line pressure to 0 psig on a power failure.

Manual override: Switch the AUTO/MAN toggle switch to the MAN position. Turn the shaft on the MAN pot to vary the pneumatic output. Return AUTO/MAN switch to AUTO position when finished.

Override Terminals (OV): When manual override switch is in manual position, contact between terminals is closed. When manual override switch is in auto position, contact between terminals is open.

Power Supply Voltage:	24 VDC or 24 VAC (+/- 10%) at EPW2 terminals
Supply Current:	160 mA max. (200 mA max. FS model)
Feedback Signal Output:	Factory Calibrated 0-5 VDC = selected span
Accuracy:	1% @ room temperature, 2% full scale temperature

Air Supply:	Maximum 25 psig, minimum 20 main air supply factory calibrated at 0-15 psig output Air Flow @ 20 psig main/15 psig out, Supply valve 750 scim, Exhaust rate: EPW2 - 750 scim, EPW2 FS - 750 scim.
-------------	---